

Machine Safety – Before Operations

Toolbox Talks are intended to facilitate health and safety discussions on the job site. For additional Toolbox Talks, please visit SAFETY.CAT.COM™.

SAFETY.CAT.COM™

TOPIC: Machine Safety—Before Operations

Pre-Start Procedures

- Read and understand the Operation and Maintenance Manual
- Always perform a pre-shift walk around inspection
- Clear all personnel and obstacles from the machine path.
- Turn battery disconnect switch to "ON."
- Clean and secure all windows and doors.
- Adjust mirrors for optimum vision.
- Adjust seat for pedal operation and operator's height and weight.
- Inspect and fasten seatbelt or harness.
- Sound horn prior to start-up.
- Start engine from operator's compartment only.

After Starting Machine

- Allow engine to warm up at low idle.
- Conduct monitoring system test per Operation and Maintenance Manual (if applicable).
- Check panel indicator lights and gauges frequently.
- Check transmission oil level (if applicable).
- Perform brake checks (per Operation and Maintenance Manual).

Preparing to Move

- Sound horn according to site regulations (allowing three to five seconds after to enable anyone to get out of the way).
- Raise all lowered implements
- Push on the service brake pedal and disengage parking brake.
- Unlock transmission and move control lever to desired gear.
- Release the service brake pedal

Disc	Discussion Date:						
Emr	Novoo	Dortio	inante				
Employee Participants:							

The material in this document is provided for informational

purposes only and not as a comprehensive or exhaustive resource on this topic. This material has been compiled from

a multitude of sources believed to be accurate; however, Caterpillar Inc. assumes no responsibility for the accuracy or

currency of this information and encourages you to consult experts in this area for more information. In no event does the content of this document supersede any applicable local, state, or federal statutes or regulations.

SAFETY.CAT.COM™ http://safety.cat.com/toolbox

