DIESEL GENERATOR SET






Image shown may not reflect actual package

PRIME 3600 ekW 4500 kVA 60 Hz 1800 rpm 12470 Volts

Caterpillar is leading the power generation Market place with Power Solutions engineered to deliver unmatched flexibility, expandability, reliability, and cost-effectiveness.

FUEL/EMISSIONS STRATEGY

Low BSFC

DESIGN CRITERIA

 The generator set accepts 100% rated load in one step per NFPA 110 and meets ISO 8528-5 transient response.

FULL RANGE OF ATTACHMENTS

- Wide range of bolt-on system expansion attachments, factory designed and tested
- Flexible packaging options for easy and cost effective installation

SINGLE-SOURCE SUPPLIER

 Fully prototype tested with certified torsional vibration analysis available

WORLDWIDE PRODUCT SUPPORT

- Cat[®] dealers provide extensive post sale support including maintenance and repair agreements
- Cat dealers have over 1600 dealer branch stores operating in 200 countries.
- The Cat[®] S•O•S[™] program effectively detects internal engine component condition, even the presence of unwanted fluids and combustion by products.

CAT C175-20 DIESEL ENGINE

- Reliable, rugged, durable design
- Four-stroke diesel engine combines consistent performance and excellent fuel economy with minimum weight

CAT SR5 GENERATOR

- Designed to match performance and output characteristics of Cat diesel engines
- Single point access to accessory connections

CAT EMCP 4 CONTROL PANELS

- Simple user friendly interface and navigation
- Scalable system to meet a wide range of customer needs
- Integrated Control System and Communications Gateway

60 Hz 1800 rpm 12470 Volts



FACTORY INSTALLED STANDARD & OPTIONAL EQUIPMENT

System	Standard	Optional		
Air Inlet	Air cleaner, 4 x single element canister with service indicator(s) Division for air inject about off	[] Air cleaner, 4 x dual element with service indicator(s)		
Cooling	Plug group for air inlet shut-off SCAC cooling Jacket water and AC inlet/outlet flanges	[] Air inlet adapters [] Remote horizontal SCAC radiator [] Remote fuel cooler [] Low coolant level sensor (for remote radiators)		
Exhaust	Dry exhaust manifold Bolted flange (ANSI 8" & DIN 200) with bellow for each turbo (qty 4)	[] Engine Exhaust Temperature Module [] Mufflers (15 dBA,25 dBA, or 40 dBA) [] Dual 20" or single 24" vertical exhaust collector [] Weld flanges: ANSI 20" and ANSI 24"		
Crankcase Systems	Open crankcase ventilation	[] Crankcase explosion relief valve		
Fuel	Primary fuel filter with water separatorSecondary fuel filters (engine mounted)			
Generator SR5	 3 phase brushless, salient pole Space heater kit IEC platinum stator RTD's Cat digital voltage regulator (CDVR) 	[] Oversize generators [] Power connection arrangement		
Governor	• ADEM™ A4	[] Redundant shutdown		
Control Panels	EMCP 4.2 Genset Controller	[] Local & remote annunciator modules [] Discrete I/O module [] Generator temperature monitoring & protection [] Remote monitoring [] Load share module		
Lube	 Lubricating oil Oil filter, filler and dipstick Oil drain line with valves Fumes disposal Gear type lube oil pump Integral lube oil cooler Electric prelube pumps 			
Mounting	Rails-engine / generator Rubber anti-vibration mounts (shipped loose)	[] Spring type linear vibration isolators [] IBC vibration isolators		
Starting / Charging	 Dual 24 volt electric starting motors Batteries with rack and cables Battery disconnect switch 	[] Oversized battery set [] 75 amp charging alternator [] Battery chargers (20,35 or 50 Amp) [] Jacket water heater [] Redundant Electric Starter		
General	 RH service (Except LH Service Oil Filter) Paint - Caterpillar Yellow with high gloss black rails SAE standard rotation Flywheel and flywheel housing - SAE No. 00 	[] Barring group- manual or air powered [] Factory test reports		

60 Hz 1800 rpm 12470 Volts



SPECIFICATIONS

CAT GENERATOR

Frame	3055
Excitation	PM
Pitch	0.6667
Number of poles	4
Number of bearings	2
Number of Leads	6
Insulation	Class F
IP rating	Drip proof IP23
Over speed capability - % c	of rated125%
Wave form deviation	3 %
Voltage regulator	3 phase sensing with
:	selectable V/Hz regulation
Telephone Influence Factor	Less than 50
Harmonic Distortion	Less than 5%

CAT DIESEL ENGINE

C175-20 SCAC, V-20, 4 stroke, water-cooled diesel

Bore	175.00 mm (6.89 in)
Stroke	220.00 mm (8.66in)
Displacement	105.8 L (6456.31 in ³)
Compression ratio	15.3:1
Aspiration	TA
Fuel system	Common Rail
Governor Type	ADEM™ A4

CAT EMCP 4 CONTROL PANELS

EMCP 4 controls including:

- Run / Auto / Stop Control
- Speed Adjust
- Voltage Adjust
- Engine Cycle Crank
- Emergency stop pushbutton

EMCP 4.2 controller features:

- 24-volt DC operation
- Environmental sealed front face
- Text alarm/event descriptions
- True RMS AC metering, 3-phase, ±1% accuracy.

Digital indication for:

- RPM
- DC volts
- Operating hours
- Oil pressure (psi, kPa or bar)
- Coolant temperature
- Volts (L-L & L-N), frequency (Hz)
- Amps (per phase & average)
- Power Factor (per phase & average)
- kW (per phase, average & percent)
- kVA (per phase, average & percent)
- kVAr (per phase, average & percent)
- kW-hr (total)
- kVAr-hr (total)

Warning/shutdown with common LED indication of shutdowns for:

- Low oil pressure
- High coolant temperature
- Overspeed
- Emergency stop
- Failure to start (overcrank)
- Low coolant temperature
- Low coolant level

Programmable protective relaying functions:

- Generator phase sequence
- Over/Under voltage (27/59)
- Over/Under Frequency (81 o/u)
- Reverse Power (kW) (32)
- Reverse Reactive Power (kVAr) (32RV)
- Overcurrent (50/51)

Communications

- Customer data link (Modbus RTU)
- Accessory module data link
- Serial annunciator module data link
- 6 programmable digital inputs
- 6 programmable relay outputs (Form A)
- 2 programmable relay outputs (Form C)
- 2 programmable digital outputs

60 Hz 1800 rpm 12470 Volts



Technical Data

Open Generator Set - 1800 rpm/60 Hz/12 470 Volts	DM8858	
Low BSFC		
Generator Set Package Performance		
Genset Power rating @ 0.8 pf	4500 kVA	
Genset Power Rating & 0.6 pt	3600 ekW	
Fuel Consumption	3000 ekvv	
100% Load with fan	922.4 L/hr	243.7 Gal/hr
75% Load with fan	922.4 L/III 667.6 L/hr	243.7 Gai/III 176.4 Gal/hr
50% Load with fan	471.6 L/hr	176.4 Gal/III 124.6 Gal/hr
Inlet Air	47 1.0 1/111	124.0 Gai/111
Combustion air inlet flow rate	308.7 m ³ /min	10902 cfm
Exhaust System		
Exhaust stack gas temperature (engine out)	458.9 °C	858 °F
Exhaust gas flow rate	774.1 m ³ /min	27335 cfm
Exhaust system backpressure (maximum allowable)	6.7 kPA	26.9 in water
Heat Rejection		
Heat rejection to cooolant (total)	1858 kW	105636 Btu/min
Heat rejection to exhaust (total)	3439 kW	195544 Btu/min
Heat rejection to aftercooler	348 kW	19792 Btu/min
Heat rejection to atmosphere from engine	320 kW	18206 Btu/min
Heat rejection to atmosphere from generator	190 kW	10815 Btu/min
Alternator		
Motor starting capabiliy @30% voltage dip	10728 skVA	
Frame	3055	
Temperature Rise	105 °C	189 °F
Lube System		
Sump refil with filter	675 L	178.3 gal
Emissions (Nominal) ²		
NOx g/hp-hr	5.7 g/hp-hr	
CO g/hp-hr	0.61 g/hp-hr	
HC g/hp-hr	0.17 g/hp-hr	
PM g/hp-hr	0.04 g/hp-hr	

Note: This generator set is not offered with an engine driven radiator. Addition of an engine driven fan will reduce the output below the nameplate rating.

¹ Some packages may have oversized generators with a different temperature rise and motor starting characteristics. Generator temperature rise is based on a 40 degree C ambient per NEMA MG1-32.

² Emissions data measurement procedures are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1 for measuring HC, CO, PM, NOx.

Data shown is based on steady state operating conditions of 77°F, 28.42 in HG and number 2 diesel fuel with 35° API and LHV of 18,390 btu/lb. The nominal emissions data shown is subject to instrumentation, measurement, facility and engine to engine variations. Emissions data is based on 100% load and thus cannot be used to compare to EPA regulations which use values based on a weighted cycle. Emissions values are tailpipe out with aftertreatment installed. Values shown as zero may be greater than zero but were below the detection level of the equipment used at the tie of measurement.

60 Hz 1800 rpm 12470 Volts



RATING DEFINITIONS AND CONDITIONS

Meets or Exceeds International Specifications: AS1359, CSA, IEC60034-1, ISO3046, ISO8528, NEMA MG 1-22, NEMA MG 1-33, UL508A, 72/23/EEC, 98/37/EC, 2004/108/EC

Prime - Output available with varying load for an unlimited time. Average power output is 70% of the prime power rating. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year. Prime power in accordance with ISO3046. Prime ambients shown indicate ambient temperature at 100% load which results in a coolant top tank temperature just below the alarm temperature.

Ratings are based on SAE J1349 standard conditions. These ratings also apply at ISO3046 standard conditions

Fuel Rates are based on fuel oil of 35° API [16° C (60° F)] gravity having an LHV of 42 780 kJ/kg (18,390 Btu/lb) when used at 29° C (85° F) and weighing 838.9 g/liter (7.001 lbs/U.S. gal.). Additional ratings may be available for specific customer requirements, contact your Caterpillar representative for details. For information regarding Low Sulfur fuel and Biodiesel capability, please consult your Cat dealer.

60 Hz 1800 rpm 12470 Volts



DIMENSIONS

Package Dimensions					
Length	6719 mm	267.5 in			
Width	2377 mm	93.6 in			
Height	2556 mm	100.6 in			

NOTE: For reference only - do not use for installation design. Please contact your local dealer for exact weight and dimensions.

www.Cat-ElectricPower.com

©2012 Caterpillar All rights reserved.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.

CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

Sourced: U.S. Sourced EPD0073-C (03/2012)