EMERGENCY TEMPERATURE CONTROL PLANNER:

Your PRACTICAL GUIDE to sustaining comfort and protecting critical processes during electric utility outages.

Temperature control is critical to your business. You need reliable cooling and heating to maintain process efficiency and output and keep your employees comfortable and productive. It's critical to prepare for outages; a failure can put your profits at risk. With a solid contingency plan, you'll know what to do and whom to call to keep your critical temperatures in control, your business functioning, and your revenues flowing.

This Temperature Control Planner will guide you and your team through the basic steps of building a contingency plan. The checklist format will help you cover the key elements quickly and easily. To fill in the details, consult with an established supplier of rental temperature control equipment, supplies, and service. Remember, the next storm or natural disaster may already be brewing. The time to plan is now.

Important Notice: Running mechanical equipment can be dangerous. Use qualified personnel to size and operate the equipment.

Step 1: DECIDE WHAT KIND OF EQUIPMENT YOU NEED. There are three basic types of short-term temperature- control equipment. Decide which will best suit your facility's purposes:
□ Fluid cooling systems use a heat exchanger or process tank to maintain the temperature of a liquid.
Air conditioners maintain air temperature, moisture, movement and cleanliness in a work space, and can be combined with fluid cooling systems to achieve unlimited cool air production.
Dense air injection supplies chilled, oxygen-rich air to maintain efficiency in a gas turbine or petrochemical refining process.

Step 2: DETERMINE THE CAPACITY REQUIRED. In an emergency, you can provide temporary equipment for all your cooling loads or for critical loads only. You must decide where optimum temperatures need to be maintained:

Computer/server rooms	kW	_tons	\Box Office space heating/cooling	kW	tons
□ Refrigerators/freezers	kW	_tons	Plant heating/cooling	kW	tons
Process	kW	_tons	□ Other	kW	tons
□	kW	_tons	□	kW	tons
□	kW	_tons	□	kW	tons
□	kW	_tons			
	kW	_tons	TOTAL	kW	tons

Step 3: CONSIDER SITE-SPECIFIC REQUIREMENTS. There are a number of factors you will need to consider and discuss with your temperature control rental equipment supplier, including:				
Approximate length of time equipment will be needed.	Amount of fluid pressure on the chiller.			
Electric power supply voltage.	Kind of fluid running through the chiller.			
□ Supply temperature required.				
Return temperature required.	□ Contaminants present in the fluid.			
□ Chilled fluid flow rate required.				

Step 4: DETERMINE THE NECESSARY EQUIPMENT FEATURES. There are many kinds of temperature control equipment on the rental market. You can choose from a variety of features to suit your site's specific requirements. Features to consider include:

CHILLERS

- **Complete package** including pumps, triple-duty valves and suction strainers reduces after-order expense.
- **Standard connections** provide fast, easy, flexible hookup to the existing system.
- Air cooled eliminates cost of water treatment, cooling tower inspections, additional piping.
- □ Water cooled for larger tonnage applications with low kW/ton power usage.
- □ **Variable-flow water pumps** accommodate a wide range of cooling and head requirements.
- **Computerized controls** enable hands-free starting and stopping.
- □ Motor-control center with disconnect switches ensures full compliance with NEC or CE codes.

AIR HANDLERS & SELF-CONTAINED AIR CONDITIONING UNITS

- **Multiple air supply and return connections** provide maximum on-site flexibility.
- □ Variable-frequency drive enables airflow adjustments to suit the application. (Smaller units may use adjustable inlet guide vanes.)
- Double-wall construction with insulation reduces noise for employee comfort and compliance with noise ordinances and regulations.
- Heating elements provide precise control of temperature and relative humidity in heating and cooling applications.

ALL TEMPERATURE CONTROL UNITS

- Sound attenuation is recommended if your facility is close to homes or other businesses. Ask for ratings below 92 db(A) at full load. Ratings as low as 70-72 db(A) available.
- □ Sight gauges simplify monitoring of critical fluid levels.
- Security features such as lockable doors, interior-mounted oil/water drains, and hidden exterior fuel drains help prevent tampering.
- **Fuel priming pump** facilitates start-up after transport.

Cooling towers	□ Hoses	
☐ Air handlers	Hose ramps	
□ Heat exchangers	Valves	
Circulation tanks	Oil-free air compressors	
Ductwork	Generators	
□ Diffusers	Other	
Pumps		

 Designated access route for delivery. Openings for hoses, piping, ductwork (louvers, weatherhead, access door). Planned route for hoses, piping, ductwork inside and outside the building. Security fencing.

Step 7: CHOOSE YOUR TEMPERATURE CONTROL EQUIPMENT SUPPLIER. To implement a successful plan, look for a rental dealership that has the equipment and accessories you need and personnel qualified to provide: □ Well maintained and pre-tested equipment. Staff qualified to deliver turnkey service and technical support. Rental units in stock that meet your load requirements. Experience in your industry. □ Modern equipment meeting emissions standards, designed for rental use. □ Capability to train your staff. □ Complete ancillary equipment in stock. Flexible financial options that include weekly and monthly rental contracts; rental purchase options. Ability to deliver to meet your time constraints. □ Pre-approved credit arrangements. □ Quick, efficient delivery and pickup. □ 24-hour response including weekends and holidays. □ Spare parts inventory in stock.

Step 8: PROVIDE FOR GENERATOR FUELING IF APPLICABLE. A reliable fuel supply is essential for emergency operation. You should arrange for fuel service in advance, ideally through your rental equipment supplier or through another source if necessary. Considerations include:
Tank capacity. Determine the fuel consumption rate of the generator set that powers your temperature control system. The unit should be able to operate for at least eight hours between refuelings.
\Box Auxiliary fuel. Having an auxiliary fuel tank enables longer runs between refuelings.
Delivery access. Make sure you can provide a clear and easily navigable access route for fuel delivery vehicles.
□ Spill containment. Regulations typically require containment equal to 110% of tank capacity.
Credit approval. Prior credit approval from the fuel supplier is essential to keep emergency operations on track.

Step 9: CONDUCT A DRY RUN. Practice makes perfect. If you want your plan to work in a real emergency, you must practice its execution beforehand. Stage a drill in which your team and, ideally, your equipment supplier run through the plan step by step, just as if an emergency were really happening.

- □ Make sure that each person fully understands his or her role in the event of an actual equipment outage.
- Estimate how long it takes from the time the temperature control system goes down until your emergency temperature control system is back on line.

Step 10: DESIGNATE EMERGENCY PERSONNEL. On the enclosed sheet, list the key contacts who will be in charge during emergencies and shutdowns. Make this list accessible to your team members and keep it up-to-date. Be sure to include a primary contact and alternate for each of the following job functions:						
□ In-house operations/maintenance	🗌 Rental equipment representative	Process engineer or contractor				
🗌 IT, security, data recovery	🗌 Equipment hookup	Electrical engineer or contractor				
□ Electric utility representative □ Equipment operation □ Fuel supplier						

A FINAL WORD. We are a supplier of complete temperature control systems for emergencies, special events, planned shutdowns and other short-term events. Our engineers and field technicians are experienced in applications of every size, in every sector. We are prepared to answer your questions about temperature control contingency planning and to be your business partner the next time the need arises.

NAME & FUNCTION	E-MAIL	OFFICE PHONE	MOBILE PHONE	HOME PHON

USEFUL FORMULAS

Temperature Differential (TD)	=	<u>TR x 24</u> GPM
Flow Rate (GPM)	=	<u>TR x 24</u> TD
Tons of Refrigeration (TR)	=	<u>TD x GPM</u> 24
Blended Temperatures (BT)	=	$\frac{F1 \times T1}{ft} + \frac{F2 \times T2}{ft}$
Heat Loss/Gain (Q)	=	$U \times A \times (tI - tO)$
Cooling Tower Ton (CTR)	=	<u>GPM x TD x 500</u> 15000
Cooling Tower BTUs Per Hour (Btu/Hr)	=	GPM X TD X 500
Cooling Tower Evaporation Rate	=	3 GPM/100 TR/Hr = 1/2 Evap Rate w/Treatment
Cooling Tower Bleed Rate	=	Evap Rate w/o Treatment

COMMON ABBREVIATIONS

TD	Temperature Differential (Delta T or ΔT)	
TR	Tons of Refrigeration	
GPM	Gallons per Minute	and the second
BTU	British Thermal Unit	
F (1, 2, 3 etc.)	Flow in Stream	HALL MARKET
T (1, 2, 3 etc.)	Temperature of Stream	
FT	Flow Total	
Q	Quantity of Heat either Lost or Gained	
tl	Temperature Inside	
tO	Temperature Outside	
А	Surface Area	e e e
U	U Factor (inverse of R factor)	

Contact your local Cat[®] dealer for support on sizing, planning, and a facility walk through.

1-800-Rent-Cat | catrentalstore.com

LEXE1563-00 (6-19)

© 2019 Caterpillar. All Rights Reserved. CAT, CATERPILLAR, LET'S DO THE WORK, their respective logos, "Caterpillar Yellow", the "Power Edge" and Cat "Modern Hex" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

