

# FB250-2A Prime rating

Meets latest India CPCBII as per G.S.R 771(E) dated 11/12/2013 and its further amendments.

Meets CPCB / MOEF norms as per G.S.R 371(T) dated 17/05/2002 and its further amendments.



## **Genset Technical Data**

Genset Rating (kVA)	250
No of Phases	3
Power Factor	0.8
Voltage (V)	415/230
Frequency (Hz)	50
Current (A)	350
Controller Type	SEDEMAC GC1203
Starting System	24V / 105 AH
Genset Weight (kg)	3100
Noise @ 75% load (dBA)	< 75 @ 1m (As per ISO 8528)
Genset Dimensions (LxWxH) (mm)	4520X1540X2100
Battery Type	Lead Acid
Circuit Breaker Rating (A)	400

### **Engine Technical Data**

AL8NTIDG6
1500
7.98
200
6
112
135
17.5 : 1
TA
Liquid Cooled
46
Electronic A0

\*sp.gr of fuel - 0.835kg/litre Standard operating conditions as per ISO3046 / ISO8528 Prime Rating as per ISO8528


# Alternator Technical DataAlternator MakeLeroy SomerNo of Bearings1Alternator modelLSAP 45 L1Alternator rating250Class of insulationHCoupling detailsSAE 14

Voltage Variation (%)	
Rated Full Load Current (A)	

1 350

# Fuel & Oil Systems Technical Data

Fuel System	Inline FIP
Type Of Fuel	Diesel
Genset Fuel Tank Capacity (I)	480
Fuel Consumption - @ 100% Load (l/hr)*	54.2
Fuel Consumption - @ 75% Load (I/hr)*	40.3
Fuel Consumption - @ 50% Load (I/hr)*	27.4
Fuel Consumption Tolerance	5%
Lube Oil change period (hrs)	500 Hrs. or 6 Month
Oil Type	15W40
Oil Capacity (I)	27
Oil Consumption @100% load	< 0.1% of FC



Caterpillar (NI) Limited is the manufacturer of FG Wilson brand diesel generating sets, and our facilities manufacture products in the following locations: Brazil • China • India

With headquarters in Northern Ireland, FG Wilson products are distributed through a Global Dealer Network. To contact your local Sales Office, please visit the FG Wilson website at www.fgwilson.com