

## Data Centre Continuous Ratings

14/12/21

FG Wilson\* has established, in conjunction with Perkins Engine Company Limited “Perkins”, a continuous rating for engines operating in data centre applications called Data Centre Continuous Ratings (DCC). Please refer to the table below for the DCC ratings which have been rated for unlimited hours of operation, with no restrictions on average variable load factor up to 100% constant load. 10% overload for 1 hour in every 12 hours operation is available within the rating, if not otherwise stated. These ratings are consistent with the requirements of the Uptime Institute’s Tier III /IV classification.

Generator Set Model	Engine Model	Engine GEP (kWm)	Alternator Model	Generator Set DCC Rating (kVA)	Generator Set DCC Rating (kWe)
P250-5	1506A-E88TAG2	213	LL5114H	230	184
P275-2	1506D-E88TAG3	236	LL5114H	250	200
P275-5	1506A-E88TAG3	236	LL5114H	250	200
P300-4	1506D-E88TAG4	258	FG26A230/LL5114J	275	220
P300-5	1506A-E88TAG4	258	FG26A230/LL5114J	275	220
P330-5	1506A-E88TAG5	281	FG26A250/LL5114J	300	240
P400-3	2206A-E13TAG2	324	FG29A280/FGL50070	350	280
P450-2	2206D-E13TAG3	367	FG29A320/FGL60010	400	320
P450-3	2206A-E13TAG3	368	FG29A320/FGL60010	400	320
P500-3	2506A-E15TAG1	412	FG29A360/FGL60020	455	364
P550-2	2506D-E15TAG2	453	FG29A400/FGL60020	500	400
P550-3	2506A-E15TAG2	451	FG29A400/FGL60020	500	400
P605-3	2806A-E18TAG1	495	FG33A450/FGL60040	550	440
P660-3	2806A-E18TAG1A	540	FG33A500/FGL60050	600	480
P715-3	2806A-E18TAG2	584	FG33A560/FGL60060	650	520
P780-1	2806A-E18TTAG4	623	LL7224J	706	564
P730P1	4006-23TAG2A	658	LL7224J	730	584
P850-1	2806A-E18TTAG5	676	LL7224L	770	616
P900-1	4006-23TAG3A	705	FGL70030/LL7224L	800	640
P1000-1	4008TAG1A	805	FGL70040/LL7224N	910	728
P1100-1	4008TAG2A	899	FGL70050/LL7224P	1000	800
P1250-1	4008-30TAG3A	997	LL8224H	1125	900
P1375-1	4012-46TWG2A	1113	LL8224H	1250	1000
P1500-1	4012-46TWG3A	1207	LL8224L	1350	1080
P1650-1	4012-46TAG2A	1331	LL8224N	1500	1200
P1760-1	4012-46TAG3A	1500	LL8224P	1600	1280
P1875-1	4012-46TAG3A	1500	LL9324F	1700	1360
P1800P3 <sup>1</sup>	4012-46TAG3A	1564	LL9324F	1800	1440
P2000-3	4016-61TRG1	1648	LL9324F	1850	1480
P2250-3	4016-61TRG2	1774	LL9324H	2000	1600
P2500-3	4016-61TRG3	1975	LL9324P	2250	1800
P2500-1D <sup>1</sup>	4016-61TRG3X	2183	LL9324R	2500	2000

Note 1: Please contact your FG Wilson Regional Sales Manager for more details on this specific rating, this rating does not offer 10% overload.

The DCC ratings are based on Normal temperature and pressure (NTP) site conditions 25°C (77°F) Air Inlet Temp, 100m (328 ft) A.S.L. & 30% relative humidity. Contact your Regional Sales manager for site specific derating.

\*FG Wilson is a trading name of Caterpillar (NI) Limited.



All sales made by Caterpillar (NI) Limited are made strictly in accordance with and under the conditions of sale, available on request.

Caterpillar Confidential. Registered office: Old Glenarm Road, Larne, BT40 1EJ. Registered in Northern Ireland No. NI 06692. VAT No. GB 254733945

